



GUAM WATERWORKS AUTHORITY

Paul J. Kemp, M.S. 688 Route 15, Mangilao GU 96913
 AGM Compliance and Safety Ph: 671 300 6885

File Opened: 07/12/2016 11:53:00 AM
 This Print: 08/26/2016 7:32:31 AM
 File Name : C:\dox\SDWA\PFOA-PFOS\UCMR3-PFOS-PFHxS-Summary.xlsx
 Subject: UCMR3 Data
 Project: PFO-compound Data
 CO No. N/A

UCMR 3 DATA ON PFOS - PFHxS				
Well No.	March 18 2015		September 30,2015	
	PFOS	PFHxS	PFOS	PFHxS
	ng/L	ng/L	ng/L	ng/L
NAS-1	67	44	110	68
A-04	N/D	32	ND	55
A-13	41	N/D	N/D	N/D
A-23	88	31	160	51
A-25	220	71	410	140
A-30	N/D	30	66	51
PROPOSED ADVISORY LEVEL 70 ng/L				
INITIAL RESAMPLING				
Location	August 11, 2016			
	PFOS	PFHxS		
	ng/L	ng/L		
NAS-1	N/D	N/D		
A-04	N/D	39		
A-13	67	N/D		
A-23	120	52		
A-25	220	130		
A-30	N/D	30		
Agana Heights Tank	120	60	NOTE: This datum indicates that blending may be workable for the Sinajana Agana Heights tank system. It is important to recognize that not all clean wells available were in use for the sampling period	
TMW	N/D	N/D		
TMW Tank	N/D	N/D		
GIAA-1	110	42		
GIAA-2	160	42		
GIAA-3	Off line - no sample			
GIAA Tank	42	38		
Notes				
PFO = perfluorooctane				
PFHp = perfluoroheptane				
PFHx - Perfluorohexane				