



## GUAM WATERWORKS AUTHORITY

“Better Water. Better Lives.”

Gloria B. Nelson Public Services Building  
688 Route 15, Mangilao, Guam 96913  
PH: 300-6026/6027 Fax: 649-3750

### **GWA IFB No. 2018-04 relative to Vertical Turbine Pump and Motor GWA Response to Inquiries No. 1**

This Addendum and Response to Request for Information (RFI) is issued to modify the previously issued bid documents and/or given for informational purposes and to the extent the responses below modify the bid documents, please treat them as an amendment to the Bid. The following responses are in response to RFIs received from potential bidders on March 02, 06, 07 and 13, 2018.

REFERENCE:	QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
<b>Questions from March 02, 2018</b>		
1.	Our pump supplier is requesting that they need to know the depth of the well or basin where these pumps will be installed to properly size the pumps.	The depth is 10 feet 8 inches. Please see Exhibit A (pump layout)
<b>Questions from March 06, 2018</b>		
2.	The manufacture has the following inquiries. <ul style="list-style-type: none"><li>• What is the pump length?</li><li>• What is the serial number to ensure the right pump is quoted?</li></ul>	Please see Exhibit A (Pump layout)  At this moment GWA is unable to advise the serial number, due to the age of the pump and is unreadable.
<b>Questions from March 07, 2018</b>		

3.		Do you know how deep is the pit for the pump? I would need to know in order to get an idea of the column length.	The depth is 10 feet 8 inches. Please see Exhibit A (pump layout)
<b>Questions from March 07, 2018</b>			
4.		<p>As per Section C of this bid, the following questions are submitted for clarification for our proposed bid submission:</p> <ol style="list-style-type: none"> <li>1. Can GWA provide a drawing as to the Length of the column/bowl assembly?</li> <li>2. Can GWA provide details on the installation or the pit depth? And Sump Size?</li> </ol>	<p>Yes. Please see Exhibit A (pump layout)</p> <p>Please see Exhibit A (pump layout)</p>

Bidders are also notified to visit GWA website: [www.guamwaterworks.org](http://www.guamwaterworks.org) to ensure that addenda to the bid, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.

3.20.18

Date



Miguel C. Bordallo, P.E.  
General Manager