



GUAM WATERWORKS AUTHORITY

Scada System for GWA's Water and Wastewater Facilities, Phase A-1
GWA Project No. E14-002-BND
IFB-02-ENG-2018
GWA RFI Response No. 3 to Bidder Inquiries

This Addendum and/or Response to Request for Information (RFI) is issued to modify the previously issued bid documents and/or given for informational purposes and to the extent the responses below modify the bid documents, please treat them as an amendment to the Bid. The following responses are in response to RFIs received.

	DATE	QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
1	02/23/18	The bidder currently is not required to have audited balance sheet(s)/financials. We request that this requirement be waived.	Please see Addendum No. 02 for revised Section 00460.
2	03/09/18	Will there be central data location where all 19 site can be monitored and controlled. If there will be a central data location, where will it be located?	Yes, there will be. The central data location is located in the Gloria B. Nelson Public Service Building.
3	03/09/18	Can we use siemens brand for this project.	In general, yes, you can use Siemens brands as permitted in the Bid Documents. More Specifically, please refer to Specification in the Bid Documents for which brand GWA will accept for specific products. Bidders shall adhere to Bid Documents for the purpose of bidding. Refer to Section 01 25 00 Substitution Procedures for use during construction.
4	03/09/18	The plan show serial MODBUS for the connection of devices to the PLC. Can we substitute MODBUS TCP/IP for the serial MODBUS connections?	Yes, MODBUS TCP/IP will be allowed. Bidder is responsible for providing all appurtenances in Bid and execution.

5	03/09/18	If the specification require a specific manufacturer and model number and that particular model number is no longer available what will the options be for the contractor to substitute with a change order?	Please refer to Section 01 25 00. The situation described would fall under 012500.1.A.1 Substitutions for Cause.
---	----------	--	--

Bidders are also notified to visit GWA website: www.guamwaterworks.org to ensure that addenda to the bid, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.



MIGUEL C. BORDALLO, P.E.
General Manager

MCB:gb
