



GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building
688 Route 15 | Mangilao | Guam 96913

Invitation For Bid: IFB-07-ENG-2019
Pressure Zone Realignment Construction- Phase 1
GWA Project No. W18-001-BND

Addendum No.: 02

Date: November 8, 2019

All Potential Bidders:

This addendum is issued to modify the previously issued bid documents and/or given for informational purposes, and is hereby made a part of the bid documents. Failure to acknowledge receipt of this addendum shall be grounds for the bidder's disqualification and rejection of the bidder's proposal.

1. Bid Documents – Invitation to Bid and other sections of the bid documents where applicable:
 - a. Bid Proposals deadline has been extended from 3:00 p.m., November 15, 2019 to **3:00 p.m., November 22, 2019.**

Bidders are also notified to visit GWA website: www.guamwaterworks.org to ensure that all addenda to the bid, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.


MIGUEL C. BORBALLO, P.E.
General Manager


MCB; gy



GUAM WATERWORKS AUTHORITY


Pressure Zone Realignment Construction- Phase I
 GWA Project No. W18-001-BND
 IFB-07-ENG-2019
 GWA RFI Response No. 2 to Contractor Inquiries

This Addendum and/or Response to Request for Information (RFI) is issued to modify the previously issued bid documents and /or given for informational purposes and to the extent the responses below modify the bid documents, please treat them as an amendment to the Bid. The following responses are in response to RFIs received.

DATE	QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
1 11/5/2019	"Technical specification of SCADA master station (SCADA software, how many SCADA servers, operator clients, UPS, network equipment's etc.)"	Project does not call for a SCADA Master Station to be installed.
2 11/5/2019	"Technical Specification of communication, such as, wireless radio"	Please refer to Spec. Section 409443, Paragraph 2.2
3 11/5/2019	<p>"What type of brand will suffice for use for the equipment and component of SCADA? Is it possible to use other brands, such as:</p> <ul style="list-style-type: none"> a. Hoffman to Saginaw b. Maple system to Schneider HMI* - full compatibility with SCADA pack c. Scadapack 334** to Scadapack 337 or latest model? (Note: **obsolete model)" 	<p>For general substitution procedures, please refer to General Conditions-00700, Paragraph 7.05.</p> <ul style="list-style-type: none"> a) See Sect. 409443, Paragraph 2.6 b) See Sect. 409443, Paragraph 2.4 c) GWA is not aware of any confirmed product obsolete at this time. In general, please refer to substitution procedures.
4 11/5/2019	"What type of wire is manufacturer cable (FE) as indicated on the plan? Can you give us a specific type of wire to be use? And TSP WIRE 2/c."	Manufacturer cable type is dependent on product per manufacturer.

5	11/5/2019	“In sheet number 42 drawing number E-102-2 in the single line diagram, the dedicated breaker for the new panel, which main is 60AT is only 30AT? Please check the diagram.”	The diagram is accurate. The 60AT allows for additional future loads.
6	11/5/2019	“For this schematic connection, can we have a detailed drawing or specs for this remote terminal unit RTU of each substation.”	Plans include typical schematics and layout diagrams; it is not meant to be prescriptive. Plans do not include full detailed panel design as it is the contractor’s responsibility to source the supplier of control panels, work with suppliers to provide appropriate design, and submit shop drawings for review prior to manufacturing.
7	11/5/2019	“In regard to the encroachment permit, will the permit be issued one time for all the sites or will it be site to site/ area to area issuance. Please confirm.”	It is the contractor’s responsibility to coordinate and obtain all permits with DPW.
8	11/5/2019	“We would like to request to consider for a two-week extension on the bid submission, there are still a lot of quotations and pricing that has yet to come back to us to be able to provide best and most competitive bid proposal.”	See Addendum No. 2.

Bidders are also notified to visit GWA website: www.guamwaterworks.org to ensure that addenda to the bid, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.



 MIGUEL C. BORDALLO, P.E.
 General Manager

MCB;jm