



GUAM WATERWORKS AUTHORITY

“Better Water. Better Lives.”
 Gloria B. Nelson Public Services Building
 688 Route 15, Mangilao, Guam 96913
 PH: 300-6027/6030 Fax: 649-3750

IFB No. 2022-03 relative to Fire Hydrant “Wet Barrel”


Response to Inquiries No. 1

This Addendum and Response to Request for Information (RFI) is issued to modify the previously issued bid documents and/or given for informational purposes and to the extent the responses below modify the bid documents, please treat them as an amendment to the Bid. The following responses are in response to RFIs received from potential bidders on March 09, 2022

REF:	QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
Questions from March 09, 2022		
1.	Item 5.1 6” Ø Dual Plate SS Check Valve. Clarification that only the dual plate, rod, lock nut, plug and cross bar are Stainless Steel. Body Construction is DI and Safety Flange is Gray Iron. Confirm this is acceptable.	Yes, this is acceptable
2.	We request at least a two-week extension from the current bid date. This is because of the disruption on pricing of the main materials and for the preparation on bid requirements, bonding etc. Also, we have experienced that courier (DHL, FED EX) are not coming in at a timely fashion for documents coming off island.	Please refer to Bid Amendment No. 1

Bidders are also notified to visit GWA website: www.guamwaterworks.org to ensure that addenda to the bid, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.

3.10.22
 Date



 Miguel C. Bordallo, P.E.
 General Manager