



GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building 688 Route 15 Mangilao, Guam 96913 | (671) 300-6058

Groundwater Wells A-02, A-07, A-12, D-05, and F-03 Rehabilitation (Re-bid)

GWA Project No. W16-001-EPA

IFB-02-ENG-2023

GWA RFI Response No. 3 to Contractor Inquiries

This Addendum and/or Response to Request for Information (RFI) is issued to modify the previously issued bid documents and/or given for informational purposes and to the extent the responses below modify the bid documents, please treat them as an amendment to the IFB. The following are responses to RFIs received:

NO.	DATE	QUESTION/INQUIRY AS SUBMITTED	GWA RESPONSE
1	12/20/2022	<ol style="list-style-type: none">1. Is the pilot hole data available? Are the pilot hole deviations within the AWWA specifications?2. What are the chances we can work 24/7 during drilling/reaming operations?3. Are the bidders allowed to bid only ONE of the bid option wells?	<ol style="list-style-type: none">1. The pilot hole data has been made available. Please see Addendum No.2 on the GWA website: http://guamwaterworks.org/bids/. It is unknown if the pilot holes meet AWWA specifications. For the plumbness and alignment requirements reamed bore hole, see Section 33 21 00, 3.05.2. Contractor may perform Work outside regular working hours only with Owner's written consent, which will not be unreasonably withheld. Refer to Section 00700, 7.03. Contractor shall be responsible for the cost of any overtime pay or other expense incurred by the Owner for Engineer's services (including those of the Resident Project Representative, if any), Owner's representative, and construction observation services, occasioned by the performance of Work on Saturday, Sunday, any legal holiday, or as overtime on any regular work day. Refer to Section 00800, SC-7.02.C.3. No, bidders are advised to fill out the bid forms completely and fully. Refer to Section 00200, Instruction to Bidders, paragraph 19.03, C.



GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building 688 Route 15 Mangilao, Guam 96913 | (671) 300-6058

NO.	DATE	QUESTION/INQUIRY AS SUBMITTED	GWA RESPONSE
2	1/9/2023	1. Due to recent holidays and the availability of local drillers, vendors that just returning from holiday breaks, we would like to request for weeks (4) weeks extension of bid due.	1. An extension has been granted in part. Refer to Addendum No.3 on the GWA website: http://guamwaterworks.org/bids/ .

Bidders are also notified to visit the GWA website, <http://guamwaterworks.org/bids/> to ensure that addenda to the IFB, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.

MIGUEL C. BORDALLO, P.E.
General Manager

MMcD

cc: MCB, JES, PF