



3.	We would like to request for a site visit to check on the existing site conditions.	3. Optional site visit granted and will be made available on January 25 <sup>th</sup> , 2023 @ 10:00am. Interested bidders should register with GWA for the optional site visit.
4.	Will the awarded bidder be responsible for the integration to the existing LCP?	<p>4 <b>Under Bidder Qualifications, page 8, Subsection A. General Requirements:</b> The awarded bidder will not be responsible for integration to existing LCP.</p> <p>In regards to the installation of VFD, the awarded bidder shall be responsible for demolishing the failed VFD units; properly mounting new VFDs in place; reconnecting Power conduits and terminating power conductors (extending or replacing with new as necessary to accommodate new VFD dimensions); reconnecting Control conduits (extending or replacing with new as necessary to accommodate new VFD dimensions). GWA will terminate control wiring to the new VFD and make control parameter changes for integration with existing LCP.</p>

Bidders are also notified to visit GWA website: [www.guamwaterworks.org](http://www.guamwaterworks.org) to ensure that addenda to the bid, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.

2023.1.18  
Date

  
\_\_\_\_\_  
Miguel C. Bordallo, P.E.  
General Manager