


“Better Water. Better Lives.”
 Gloria B. Nelson Public Services Building
 688 Route 15, Mangilao, Guam 96913
 PH: 300-6027/6030 Fax: 649-3750

**IFB No. 2023-12 relative to
 Water Pump and Motor for Ugum Treatment Plant
 Response to Inquiries No. 2**

This Addendum and Response to Request for Information (RFI) is issued to modify the previously issued bid documents and/or given for informational purposes and to the extent the responses below modify the bid documents, please treat them as an amendment to the Bid. The following responses are in response to RFIs received from potential bidders on March 03 & 06, 2023.

REF:	QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
Questions from March 03, 2023		
1.	<p>Just a clarification on the response of the RFI No. 2. The factory recommends the motor should be shipped vertically. It is not possible then to ship the pump and motor assembled together. See attached.</p> 	<p>Pump and Motor shall be shipped as per factory recommendations.</p>
Questions from March 06, 2023		
2.	<p>Just a clarification on the award. Are you awarding to the qualified bidder per line item? (1.0 pump and 2.0 motor) or as a package (whoever the lowest on the total price of the pump and motor)?</p>	<p>IFB No. 2023-12 is now an “All or None Bid” Award will be made on the Total cost for both line items.</p> <p>An all or none bid means that GWA will not award on an itemize basis. In order for an award to be made, all bid items listed <u>must</u> include a bid amount.</p>

Bidders are also notified to visit GWA website: www.guamwaterworks.org to ensure that addenda to the bid, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.

2023.3.15

Date



Miguel C. Bordallo, P.E.
General Manager