



Ugum Water Treatment Plant Rehabilitation (Re-bid)
 GWA Project No. W22-10-BND
 IFB-08-ENG-2023
 RFI Response No. **8** to Contractor Inquiries

This Addendum and/or Response to Request for Information (RFI) is issued to modify the previously issued bid documents and/or given for informational purposes and to the extent the responses below modify the bid documents, please treat them as an amendment to the Bid. The following are in response to RFIs received.

	REFERENCE	QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
Questions from June 28, 2023			
1. PIPE GALLERY/GENERATOR ROOM			
a.		I see the spec calls out for AWWA valves. Do they need to be certified AWWA? Our valves meet and mostly exceed the AWWA specifications.	<i>Valves may be or equal, contractor shall provide comparison in accordance with the general requirements of contract.</i>
2. THICKENER ASSEMBLY			
a.		The RFI references a 32 ft. diameter thickener but the as-built drawings only show a 20 ft. diameter unit. Item "F" in the RFI includes the statement: "All information available to GWA is included in the Procurement Report (re-bid) - the Installation, Operation, and Maintenance Instructions for EIMCO BST Thickener 32' dia. With W24P drive unit."	<i>Correct diameter is 20 ft. as shown in GMP's as-built drawing.</i>

Bidders are also notified to visit GWA website: <http://guamwaterworks.org/bids/> to ensure that addenda to the bid, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.



MIGUEL C. BORDALLO, P.E.
General Manager

MMcD