



**GUAM WATERWORKS AUTHORITY**

“Better Water. Better Lives.”  
 Gloria B. Nelson Public Services Building  
 688 Route 15, Mangilao, Guam 96913  
 PH: 300-6027/6030 Fax: 649-3750

**IFB No. 2023-21**  
**Hagåtña Wastewater Treatment Plant Clarifier Parts**  
**Response to Inquiries No. 3**

This Addendum and Response to Request for Information (RFI) is issued to modify the previously issued bid documents and/or given for informational purposes and to the extent the responses below modify the bid documents, please treat them as an amendment to the Bid. The following responses are in response to RFIs received from potential bidders on August 08, 2023.

REF:	QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
<b>Questions from August 08, 2023</b>		
1.	Bid Item No. 7.0 Non-Metallic Crail 100  As per the factory response. This will not be compatible with existing clarifier.	<b>Section I. BID ITEM (s)</b>  <b>Amended now to read for the following:</b> <b>Line Items: 4.0, 7.0 to 7.2.</b> <b>See attached.</b>  <b>Technical Specification for Items</b> <b>Number:</b> <b>7.0 to 7.2</b> <b>See attached.</b>

Bidders are also notified to visit GWA website: [www.guamwaterworks.org](http://www.guamwaterworks.org) to ensure that addenda to the bid, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.

2023.8.21  
 Date

  
 Miguel C. Bordallo, P.E.  
 General Manager

4.0	Bracket-Attch F28, Rh,1.5 X 9.4 X 8" Poly <b><u>Part No. W2T319529</u></b>	140	_____	_____
5.0	Chain;Convyg;HS730;Poly; 6 In P Part No. W2T319512	100	_____	_____
6.0	Chain; Convyg; HS730; Poly;6 In P Part No. W2T319515	30	_____	_____
7.0	<b>Wearing Strips</b> <b>10' UHMW, 5-Hole</b> <b><u>Part No. 303-80410-1</u></b>	<b>110</b>	_____	_____
7.1	<b>Wearing Strips</b> <b>10' UHMW, 8-Hole</b> <b><u>Part No. 303-80410-2</u></b>	<b>13</b>	_____	_____
7.2	<b>Wearing Strips</b> <b>5' UHMW, 7-Hole</b> <b><u>Part No. 303-80410-3</u></b>	<b>5</b>	_____	_____
8.0	Export and Crating	1	_____	_____
9.0	Ocean Port To Guam	1	_____	_____
			<b>Total Cost</b>	_____

**Technical Specifications Item 1.0 and 2.0**

- A. Scrapers shall be fiberglass, 3-inch by 8-inch nominal size, designed for sludge collector service. The scraper shall have continuous fiberglass filaments running the full length of the member and shall include a 1/4-inch scraper lip on the leading edge to provide cleaning of the tank floor. The scraper shall include filler blocks for bolting the member to the chain attachment links. Flight spacing shall be approximately 10 feet for the collectors. Do not use buoyant flight designs.
- B. Fiberglass scrapers shall be either of an interchangeable L-shaped or channel design and shall be guaranteed by the manufacturer to provide a minimum service life of five years under normal usage.
- C. Provide to the Owner a written guarantee for the fiberglass flights certifying limits of +1/2-inch and -1/16-inch sag and ±1-inch bow. These tolerances shall be based on

**Technical Specifications Item 7.0, 7.1 and 7.2**

**Wear strip system is attached directly to the tank floor to conform to rough concrete surfaces and uneven expansion joints. Manufactured out of UHMW PE (Ultra High Weight Polyethylene - High Molecular Polyethylene), and come in 10-foot or 5-foot lengths.**

**BIDDING ON:**

**MFG:** \_\_\_\_\_

**BRAND:** \_\_\_\_\_

**PLACE OF ORIGIN:** \_\_\_\_\_

**DATE OF DELIVERY:** \_\_\_\_\_  
(AFTER RECEIPT OF PURCHASE ORDER)

**II. GENERAL TERMS AND CONDITIONS**

**A. AUTHORITY.**

This Invitation for Bids is issued subject to all of the provisions of the Guam Procurement Act and the Guam Procurement Regulations. The bid requires all parties involved in the preparation, negotiation, performance, or administration of contracts to act in good faith. Failure on the part of any bidder to act in good faith shall serve as a basis for voiding a bid or shall constitute a material breach of any contract entered into between GWA and any bidder which shall allow GWA to immediately terminate the contract.

**B. EXPLANATION TO BIDDERS.**

Except as otherwise provided herein, no oral explanation in regard to the meaning of any provision of this Bid will be made and no oral instructions will be given before the award of the bid. Discrepancies, omissions, or doubts as to the meaning of any provision of this Bid shall be communicated in writing to the GWA Procurement Office.

**C. QUESTIONS.**

Only written comments or questions regarding this bid will be accepted. No oral representation made by any employee or agent of GWA shall bind GWA. All questions or requests for clarifications must be submitted **no later than five (5) business days prior to the bid opening schedule**. Any questions submitted after that date shall not be responded to except at the discretion of the GWA General Manager.