



GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913
P.O. Box 3010, Hagåtña, Guam 96932
Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

**Invitation for Bid Number: GWA 2024-02
For Galvanized Pipes**

Amended Version (Revised)

Indefinite Quantity Bid

This is an "Indefinite Quantity" bid pursuant to the Guam Procurement Regulations. The quantities reflected are only estimated and not a guarantee of amounts to be purchased. Quantities may increase or decrease thru the duration of the contract and continued purchase is subject to the availability of funds. No guarantee or other commitment is made to vendors in terms of purchasing quantity and the amounts set forth in this bid are only estimates of needs for the near term.

I. BID ITEM(s)

<u>ITEM NO.</u>	<u>DESCRIPTION</u>	<u>EST QTY</u>	<u>UNIT COST</u>	<u>EXTENSION</u>
1.0	4"dia. X 21' L Sch 80 Galvanized Pipe with coupling	20	\$ _____	\$ _____
2.0	5"dia. X 21' L Sch 80 Galvanized Pipe with coupling	10	\$ _____	\$ _____
			TOTAL COST:	_____

TECHNICAL SPECIFICATIONS FOR ITEMS 1.0 THROUGH 2.0

Pipes shall be schedule 80, hot-dipped zinc-coated (galvanized) steel pipe. Bidders are required to furnish evidence of compliance with ASTM A53/A53M latest edition and NSF 60/61 certification in English, at no additional cost to GWA. Non-compliance with these specifications will result in the rejection of the bid.

Pipes must be Type E (welded) or Type S (seamless) construction Grade B. Pipe ends shall be provided with taper pipe threads in accordance with ANSI B1.20.1.

Bidding On:

MFG.: _____

BRAND: _____

PLAE OF ORIGIN: _____

DATE OF DELIVERY: _____
(AFTER RECEIPT OF PURCHASE ORDER)

End of Amended Version