

GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913 P.O. Box 3010, Hagåtña, Guam 96932 Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

IFB No. 2024-16 Wastewater Treatment Chemicals for Hagåtña WWTP Response to Inquiries No. 5

This addendum serves to revise the previously issued bid documents and/or provides additional information for informational purposes. In cases where the responses below result in modifications to the bid documents, please consider them as amendments to the original IFB 2024-16. The following responses address RFIs received from potential bidders on August 12, 2024.

	QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
Questions from August 12, 2024:		
1.	Our supplier #2 says he gets the impression that GWA prefers ACH powder, and has this to ask: "we can only offer liquid – but I think there is opportunity to make a better performance – but it will be very helpful if you could share drawings on WWTP, and where they use ACH and polymer." Is GWA able to provide this information?	GWA WWTPs have been set up to use powdered ACH. GWA will accept liquid ACH as offered for trial as long as the material can be connected to GWA's existing feed system. Vendor(s) is(are) invited to visit the feed sites to satisfy themselves on what it would take to perform the full-scale trial without disrupting normal WWTP operations. An on-site visit is recommended as being of more use than copies of design plans. Copies of GWA Engineering documents require the General Manager's approval on request(s) supported by the GWA Procurement Office and signed Non-Disclosure Agreements (NDAs) by the requester. They will also have a documentation fee payment requirement if approved.

Bidders are also notified to visit the GWA website: www.guamwaterworks.org to ensure that any addenda to the bid, answers to questions, and reminders are communicated to all bidders during the solicitation process.

Vincent Guerrero
Supply Management Administrator