



**GUAM WATERWORKS AUTHORITY**

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913  
P.O. Box 3010, Hagåtña, Guam 96932  
Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

September 3, 2024

**Bid Amendment No: 1**

Invitation for Bid (IFB) 2024-11 Motor and Centrifugal Pump for NDWWTP

Prospective Bidders are hereby notified of the following:

Bid opening date scheduled for Wednesday, September 4, 2024, at 10:00 a.m. has been rescheduled.

**New bid opening date and time is scheduled for Thursday, September 19, 2024 at 2:00 p.m.**

**Amendment on line Item 3.0**

**Line Item 3.0 reads:**

Technical Specifications for Item 3.0 (Approved Equal)

Ser 45442628-1-01

Part No :

Fr : 445T

Encl : TEFC

Ph : 3

IP : 55

IC : 41

Des : B

Code : G

Insl: H4

Rise: 55 deg C

SF: 1.15

Amb: 40 deg C

Alt: 3300ft/1000m

Volts: 460

Hz: 60

HP: 150

KW: 112

RPM: 1790

Nom Eff: 95.8

FI Amps: 169

Warranty: Standard

**Line Item 3.0 to now read:**

**Technical Specifications for Item 3.0 (Approved Equal)**

Ser 45442628-1-01

Part No :

**Fr : 254T**

Encl : TEFC

Ph : 3

IP : 55

IC : 41

Des : B

Code : G

**Insl: H**

**Rise: 50 deg C**

SF: 1.15

Amb: 40 deg C

Alt: 3300ft/1000m

Volts: 460

Hz: 60

HP: 15

**Kw: 11.2**


**RPM: 1772**

**Nom Eff: 92.4**

**Fl Amps: 18.8**

Warranty: Standard

Nothing Follows.



Vincent Guerrero

Supply Management Administrator