



GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913

P.O. Box 3010, Hagåtña, Guam 96932

Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

IFB No. 2024-17 Wastewater Pump for Cha'ot Station Response to Inquiries No. 2

This addendum serves to revise the previously issued bid documents and/or provides additional information for informational purposes. In cases where the responses below result in modifications to the bid documents, please consider them as amendments to the original IFB 2024-17. The following responses address RFIs received from potential bidders on September 30, 2024.

	QUESTIONS/INQUIRIES AS SUBMITTED:	GWA RESPONSE:
1.	Piti Pump Station: 4" Discharge required. 3" Discharge available. Is it acceptable?	No
2.	PGD: 4" Discharge required. 3" Discharge available. Is it acceptable?	No
3.	Chalan Pago: 4" Discharge required. 3" Discharge available. Is it acceptable?	No
4.	Yigo: 8" Discharge required. 6" Discharge available. Is it acceptable?	No
5.	Barrigada: 8" Discharge required. 6" Discharge available. Is it acceptable?	No
6.	Leyang: Lowest available voltage for 25HP motor is 230V. 208V not available. Please advise.	Revised Specification for Line Item 9.0: The voltage requirement may be either 208V or 230V for the 25HP motor.
7.	Fema 96: 13HP Requirement seems very low for the 2047 GPM at 50FT TDH requirement. Please advise	Please refer to Response to Inquiries No. 1, Q & A No. 5. http://guamwaterworks.org/wp-content/uploads/2024/09/Response-to-Inquiries-No.-1-IFB-2024-17-mcb-Signed-9-23-2024.pdf

Bidders are also notified to visit the GWA website: www.guamwaterworks.org to ensure that any addenda to the bid, answers to questions, and reminders are communicated to all bidders during the solicitation process.

Miguel C. Bordallo, P.E.,
General Manager

Date