




**GUAM WATERWORKS AUTHORITY**  
 Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913  
 P.O. Box 3010, Hagåtña, Guam 96932  
 Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

**IFB No. 2024-16**  
**Wastewater Treatment Chemicals for Hagåtña WWTP**  
**Response to Inquiries No. 7**

This addendum serves to revise the previously issued bid documents and/or provides additional information for informational purposes. In cases where the responses below result in modifications to the bid documents, please consider them as amendments to the original IFB 2024-16. The following responses address RFIs received from potential bidders on January 13, 2025.

Questions from January 13, 2025:		GWA Response:
1.	Is GWA the one to conduct the test for compliance to USEPA NPDES permit limits at full scale testing, or does the bidder have to schedule this with EPA?	If the testing aligns with GWA's normal monitoring cycle, GWA will provide the results. If it does not coincide, the bidder is responsible for arranging the testing through a GEPA-approved laboratory during the trial period.
2.	Is GWA the one to conduct the paint filter test, or is this something the bidder should arrange? If the latter, is this something I need to schedule with EPA as well?	The bidder must replicate the GWA Paint Filter Test. GWA will provide Paint Filter Test results to Layon Landfill upon delivery.
3.	Are we able to test for CODs & BODs with GWA lab equipment, or is this something bidder must have available already to test?	The bidder is responsible for providing testing for any parameters not included in GWA's routine monitoring schedule.

Bidders are also notified to visit the GWA website: [www.guamwaterworks.org](http://www.guamwaterworks.org) to ensure that any addenda to the bid, answers to questions, and reminders are communicated to all bidders during the solicitation process.

  
 \_\_\_\_\_  
 Miguel C. Bordallo, P.E.  
 General Manager *CB*

1/21/2025  
 \_\_\_\_\_  
 Date