



GUAM WATERWORKS AUTHORITY
 Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913
 P.O. Box 3010, Hagåtña, Guam 96932
 Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

**Hagåtña Main Sewer Pump Station Redundant Force Main
 (Construction)
 IFB-04-ENG-2025
 GWA Project No. 22002
 GWA Response to RFI No. 1 Contractor Inquiries**

This Addendum and/or Response to Request for Information (RFI) is issued to modify the previously issued bid documents and/or given for informational purposes and to the extent the responses below modify the bid documents, please treat them as an amendment to the Bid. The following are responses to RFIs received:

NO.	DATE	QUESTION/INQUIRY AS SUBMITTED	GWA RESPONSE
Questions from March 11, 2025			
1		Please provide the following sewage peak influent flow listed below to identify how many sewage transfer trucks are required for temporary bypass operation. a. Inlet Manhole #1 – Influent peak flow from the North b. Inlet Manhole #2 – Influent peak flow from the South	Please refer to Specification 02 24 00, Paragraph 1.5 B for information on flows that can be used to estimate the flow coming into the pump station. Note that this data is the combined flow from both Inlet Manhole #1 and Inlet Manhole #2 based on what is received at the Hagåtña Wastewater Treatment Plant.
2		Please provide the location of Hagåtña WWTP.	Please see the Location Map below, as well as refer to sheet T-001, Location Map.



3	<p>For Drawing Sheet G-101 (Construction Sequencing Plan-1), Step 1, it appears that downstream (S36) in Inlet Manhole #1 has no plug. Please clarify if the intention is to use the Wet Well #1 and 2 as part of the temporary bypass line as a collection basin.</p>	<p>Please refer to sheet G-101_R1.</p>
---	--	--

Questions from March 14, 2025			
4		We kindly request a 4-week extension for submitting our proposals, with a revised deadline of April 30, 2025. This additional time will enable us to conduct thorough research for the project. Additionally, we request an extension for the RFI submission deadline as well.	Bid submission due date extended to April 11, 2025. (Refer to Addendum 1)
5		Could you please clarify whether the flows shown in Section 02 24 00 - 1.5 B are at the Hagåtña Wastewater Treatment Plant or at the location of the temporary bypass? In other words, should we plan to prepare a bypass plan for 9.3 MGD (worst case scenario)?	Please refer to Question 1, above. The flows listed were collected from the Hagåtña Wastewater Treatment Plant (WWTP), but Hagåtña Main Sewer Pump Station is the only pump station the sends flows to WWTP. The flows were the flow rates from the pump station to the WWTP.
6		We are actively collaborating with vendors to assess pump and material availability. However, due to ongoing supply chain challenges, the current period of performance for 410 will not be sufficient to complete the project. Is there any chance to increase period of performance by 6 months?	No. The period of performance was determined by the Partial Consent Decree requirements. The rehabilitation of the Hagåtña Main Sewer Pump Station must be completed by August 8, 2025 to satisfy the Partial Consent Decree (Case 1:24-cv-00004)
Questions from March 17, 2025			
7		Please provide list of registered bidders for the abovementioned IFB.	See Bidder's Register attached as of March 19, 2025. Please Note, as the bid has not closed, the register provided is subject to change. Additionally, as per 2 GAR §3109 (g) (3) Public Availability. <i>Names and addresses on bidders' lists shall be available for public inspection provided the</i>

			<p><i>lists shall not be used for Names and addresses on bidders' lists shall be available for public inspection provided the lists shall not be used for private promotional, commercial, or marketing purposes.</i></p>
--	--	--	---

Bidders are also notified to visit GWA website: www.guamwaterworks.org to ensure that addenda to the bid, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.



MIGUEL C. BORDALLO, P.E.
General Manager



