



## GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913

P.O. Box 3010, Hagåtña, Guam 96932


Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

### IFB No. 2025-30 Tumon Maui Well Pump & Motor Replacement Response for Inquiries No. 1

This document addresses inquiries regarding IFB 2025-30. It provides clarifications and additional information for informational purposes. In the event that any responses result in modifications to the bid documents, they should be considered as amendments to the original IFB 2025-30.

QUESTION/INQUIRY AS SUBMITTED:		GWA RESPONSE:
<b>Questions from May 7, 2025</b>		
1.	Can the motor for an 8-stage pump be a B&G/Goulds turbine and meet your specification requirement?	No, the motor for the 8-stage pump cannot be a B&G/Goulds turbine and still meet the specification requirements. As stated in the Guam Waterworks Authority Invitation for Bid Number GWA 2025-30 for the Tumon Maui Well Pump & Motor Replacement, the specification requires the Nidec Motor brand, manufactured by Nidec Motor Corporation, to ensure compatibility with the existing pump installed at the site. Procuring a motor from a different brand, such as Bell & Gossett (B&G), manufactured by Xylem Inc., would likely require modifications that are cost-prohibitive and could cause operational disruptions. Therefore, the solicitation is limited to the specified brand to maintain system compatibility, protect system integrity, and avoid unnecessary expenditures.

Bidders are also notified to visit the GWA website: [www.guamwaterworks.org](http://www.guamwaterworks.org) to ensure that any addenda to the bid, answers to questions, and reminders are communicated to all bidders during the solicitation process.

  
 \_\_\_\_\_  
 Miguel C. Bordallo, P.E.  
 General Manager

5/13/2025

\_\_\_\_\_  
Date