

Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

IFB No. 2025-31 **Ultrasonic Water Meters** Response for Inquiries No. 2

This document addresses inquiries regarding IFB 2025-31. It provides clarifications and additional information for informational purposes. In the event that any responses result in modifications to the bid documents, they should be considered as amendments to the original IFB 2025-31.

	QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:	
Questions from May 16, 2025			
1.	Can we email a technical proposal and financial proposal? If so, to what email address?	No, bid submissions are to be prepared in a sealed bid package. Kindly refer to the IFB checklist for bid submission instructions on page 4 of the BID document.	
2.	Does the financial proposal have to be password protected?	Kindly refer to the IFB checklist for bid submission instructions on page 4 of the BID document.	
3.	Is the bid guarantee essential?	Yes, it is a requirement.	
4.	We have fortunately heard from one supplier/manufacturer and has some questions which we thought of referring to you for accuracy of information. They wanted to check with us on the electronics you would like. They have two series of ultrasonic flowmeters. The QS200 meters which offer a blind pulse output (no display) or a remotely mounted display, and this option requires external power. Or they have the UM meters, which offer a battery powered local display. Which option do you prefer?	Per the specifications outlined in IFB No. 2025-31, GWA requires ultrasonic water meters equipped with a local, integrated digital display, with battery-powered operation.	

Bidders are also notified to visit the GWA website: www.guamwaterworks.org to ensure that any addenda to the bid, answers to questions, and reminders are communicated to all bidders during the solicitation process.

M3017H	5/19/2025
Miguel C. Bordallo, P.E. General Manager	Date