



## GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913

P.O. Box 3010, Hagåtña, Guam 96932




Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290


### IFB No. 2025-19 Facility Damage Repairs Caused by Mawar Response for Inquiries No. 3


This document addresses inquiries regarding IFB 2025-19. It provides clarifications and additional information for informational purposes. In the event that any responses result in modifications to the bid documents, they should be considered as amendments to the original IFB 2025-19.


QUESTION/INQUIRY AS SUBMITTED:		GWA RESPONSE:
<b>Questions from July 3, 2025</b>		
1.	<p>Kindly provide the specification of this items listed below:</p> <p>1.A42-0-10-F100FGFCH2 Odor control exhaust fan (Windward Hills Wastewater)</p> <p>2. Penn Ventilator xr 60 exhaust fan (Asan Wastewater)</p> <p>3. SQUARE D Model 6 Control (Yigo Wastewater)</p> <p>4. 270 ACRV 270R 9 B Air intake cover (Southern Link Wastewater)</p> <p>5. Exterior Light Fixture (Umatac- Merizo Wastewater Treatment)</p> <p>6. Exterior Wall Light Fixture (Umatac- Merizo Wastewater Treatment)</p> <p>7. photocell lighting (pago socio)</p> <p>8. Allen Bradley Cat No. 22F-V2P5N103 Series A (Hagatna Wastewater 2)</p> <p>9. Dusk to Dawn LED Light Fixture (Ugum Water Treatment Plant 1)</p>	<p><b>Refer to page 2 for the response.</b></p> <p><b>Attached for your use is the revised Bid Cost Form as of July 17, 2025.</b></p> <p><b>Additionally, GWA will be amending the following deadlines to provide all prospective bidders with sufficient time to update their bidding information and bid bonds as necessary.</b></p> <p style="text-align: center;"><b><u>New Deadlines as Follows:</u></b></p> <p><b>Deadline for Submission:</b> 7/29/25 at 10 am <b>Bid Opening:</b> 7/29/25 at 10:30 am</p> <p style="text-align: center;"><b><u>Bid Opening Information</u></b></p> <p><b>Date/Time</b> Jul 29, 2025, 10:30 – 11:30 AM (Pacific/Guam)</p> <p><b>Please join my meeting from your computer, tablet or smartphone.</b> <a href="https://meet.goto.com/760934077">https://meet.goto.com/760934077</a></p> <p><b>You can also dial in using your phone.</b> Access Code: 760-934-077 United States: <a href="tel:+18722403212">+1 (872) 240-3212</a></p> <p><b>Get the app now and be ready when your first meeting starts:</b> <a href="https://meet.goto.com/install">https://meet.goto.com/install</a></p>

Requested Specifications for Items


Q#	Item	Location	GWA Response
1.1	A42-0-10-F100FGFCH2 Odor Control Exhaust Fan	Windward Hills Wastewater	  
1.2	Penn Ventilator XR 60 Exhaust Fan	Asan Wastewater	Alternate spec in use: Model: 5DDU16DB Type: 16.5" Direct Drive Centrifugal Roof Ventilator Style: Modern

Q#	Item	Location	GWA Response
1.2 (Continued)	Penn Ventilator XR 60 Exhaust Fan	Asan Wastewater	Amps: 6.2/3.1 RPM: 1100 HP: ½ Voltage: 115/230 Hz: 60 Material: Aluminum
1.3	SQUARE D Model 6 Control	Yigo Wastewater	Removed from IFB. Control panels were upgraded post-Mawar.
1.4	270 ACRV 270R 9 B Air Intake Cover	Southern Link Wastewater	Removed from IFB.
1.5	Exterior Light Fixture	Umatac-Merizo Wastewater Treatment	

Q#	Item	Location	GWA Response
1.6	Exterior Wall Light Fixture	Umatac-Merizo Wastewater Treatment	

Q#	Item	Location	GWA Response
1.6 (Continued)	Exterior Wall Light Fixture	Umatac-Merizo Wastewater Treatment	
1.7	Photocell Lighting	Pago Socio	Outdoor Sodium Vapour Street Lamp – 400W LED Street Lighting
1.8	Allen Bradley Cat No. 22F-V2P5N103 Series A	Hagåtña Wastewater 2	Motor Rating: 0.4kW / 0.5HP Input: 1 Phase, 100–115V, 48–63Hz AC Range: 90–126V Input Amps: 9.0 Output: 3 Phase, 0–230V Continuous Amps: 2.5 60-sec Overload Amps: 3.75
1.9	Dusk to Dawn LED Light Fixture	Ugum Water Treatment Plant 1	ALS WNA-80-MC-DB-UNVD Wall Mounted Lights

Bidders are also notified to visit the GWA website: [www.guamwaterworks.org](http://www.guamwaterworks.org) to ensure that any addenda to the bid, answers to questions, and reminders are communicated to all bidders during the solicitation process.

  
 Thomas F.A. Cruz, P.E. Acting  
 General Manager

7/18/2025

Date



## GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913

P.O. Box 3010, Hagåtña, Guam 96932

Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

### IFB 2025-19 Facility Damage Repairs Caused by Mawar Bid Cost Form, Revised 7/17/2025

Item #	Damage #	Site	Comments	Cost
1.0	1343432	Yigo 1, 2,3, Reservoirs	Revised SOW via Bid Amendment #1	
2.0	1343433	Mataguac Water Booster Pump	Revised SOW via Bid Amendment #1	
3.0	1343434	Astumbo 1 & 2 Reservoir	Revised SOW via Bid Amendment #1	
4.0	1343437	Barrigada 1 & 2 Reservoir	Revised SOW via Bid Amendment #1	
5.0	1343438	Deepwell M-21	Revised SOW via Bid Amendment #1	
6.0	1343439	Pago Socio Wastewater Treatment Plant	Revised SOW via Bid Amendment #1	
7.0	1343440	Hagatna Wastewater Treatment Plant (1)	Revised SOW via Bid Amendment #1	
8.0	1343441	Hagatna Wastewater Treatment Plant (2)	Revised SOW via Bid Amendment #1	
9.0	1343442	Nimitz Hill Water Booster Pump (1)	Removed entirely from this IFB via Bid Amendment #1	
10.0	1343443	Nimitz Hill Water Booster Pump (2)	Removed entirely from this IFB via Bid Amendment #1	
11.0	1343444	Agat-Santa Rita Wastewater Treatment Plant	Revised SOW via Bid Amendment #1	
12.0	1343446	Umatac-Merizo Wastewater Treatment Plant (1)	Revised SOW via Bid Amendment #1	
13.0	1343447	Umatac-Merizo Wastewater Treatment Plant (2)	Revised SOW via Bid Amendment #1	
14.0	1343448	Astumbo 1 Wastewater Lift	No Changes Required	
15.0	1343449	Deepwell D-08	Removed entirely from this IFB via Bid Amendment #1	
16.0	1343450	Deepwell Y-09 (1)	Revised SOW via Bid Amendment #1	
17.0	1343451	Deepwell Y-09 (2)	No Changes Required	
18.0	1343452	Deepwell D-07	No Changes Required	
19.0	1343453	Latte Heights Submarine Wastewater Lift	Revised SOW via Bid Amendment #1	
20.0	1343455	Piti Wastewater Lift	Revised SOW via Bid Amendment #1	
21.0	1343456	Windward Hills Wastewater Lift	No Changes Required	
22.0	1344879	Ugum Water Treatment Plant (1)	Revised SOW via Bid Amendment #1	
23.0	1344941	Deepwell Y-17	Removed entirely from this IFB via Bid Amendment #1	



## GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913

P.O. Box 3010, Hagåtña, Guam 96932

Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

### IFB 2025-19 Facility Damage Repairs Caused by Mawar Bid Cost Form, Revised 7/17/2025

Item #	Damage #	Site	Comments	Cost
24.0	1345104	Southern Link Wastewater Lift	Revised SOW via RFI #3	
25.0	1345110	Ypaopao Wastewater Lift-Fencing	Revised SOW via Bid Amendment #1	
26.0	1345117	Route 16 Wastewater Lift	No Changes Required	
27.0	1345120	Hagatna Main	Revised SOW via Bid Amendment #1	
28.0	1345121	Zero Down Wastewater Lift	No Changes Required	
29.0	1345124	Harmon Wastewater Lift	Revised SOW via Bid Amendment #1	
30.0	1345125	Latte Heights Sunrise Villa Wastewater Lift	Removed entirely from this IFB via Bid Amendment #1	
31.0	1345129	Chalan Pago 3 Wastewater Lift	Revised SOW via Bid Amendment #1	
32.0	1345130	Macheche Wastewater Lift	Removed entirely from this IFB via Bid Amendment #1	
33.0	1345733	Ugum Water Treatment Plant (2)	Revised SOW via Bid Amendment #1	
34.0	1345734	Agat Chaligan Taleyfac Wastewater Lift	Revised SOW via Bid Amendment #1	
35.0	1345735	Agat Ga'an Wastewater Lift	Revised SOW via Bid Amendment #1	
36.0	1345736	Asan Wastewater Lift	Revised SOW via Bid Amendment #1	
37.0	1345740	Gayinero Water Booster Pump	Removed entirely from this IFB via Bid Amendment #1	
38.0	1345741	New Chaot Wastewater Lift	No Changes Required	
39.0	1345742	Pago Double Shaft Wastewater Lift	Revised SOW via Bid Amendment #1	
40.0	1345749	Ugum Water Treatment Plant - River Intake (2)	Revised SOW via Bid Amendment #1	
41.0	1345750	Yigo Wastewater Lift	Revised SOW via Bid Amendment #1. Additionally, the repair request for the Square D Model 6 Control has been removed from the SOW via RFI #3.	
42.0	1345747	Ugum Water Treatment Plant - River Intake (1)	No Changes Required	
Total Bid Amount:				

Company Name: \_\_\_\_\_

Date: \_\_\_\_\_

Name/Title: \_\_\_\_\_

Signature: \_\_\_\_\_