



GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913

P.O. Box 3010, Hagåtña, Guam 96932

Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

IFB No. 2025-47 Submersible Galvanized Pipes Response for Inquiries No. 1

This document addresses inquiries regarding IFB 2025-47. It provides clarifications and additional information for informational purposes. In the event that any responses result in modifications to the bid documents, they should be considered as amendments to the original IFB 2025-47.

QUESTION/INQUIRY AS SUBMITTED:		GWA RESPONSE:
Questions from August 28, 2025		
1.	In regard to this bid, can I clarify if the pipes need to be manufactured in the US? And what is the delivery time frame for the pipes?	Pipes do not have to be made in the US, however it must meet the <u>Technical Specifications</u> indicated in the bid. Delivery time shall be 120 days
Questions from September 2, 2025		
2.	Please confirm if the pipes are welded or seamless. Usually submersible pump column.	Pipes MUST be Type E (welded) or Type S (seamless) construction Grade B.

Brett E. Railey, P.E.
Acting General Manager

9/4/2025

Date