

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913 P.O. Box 3010, Hagátña, Guam 96932 Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

A-30 Deep Well Generator Building Repair GWA Project No. 12506 IFB-01-ENG-2026 GWA RFI Response No. 1 to Contractor Inquiries

This Addendum and/or Response to Request for Information (RFI) is issued to modify the previously issued proposal documents and/or given for informational purposes and to the extent the responses below modify the proposal documents, please treat them as an amendment to the RFP. The following are responses to RFIs received:

NO.	DATE	QUESTION/INQUIRY AS SUBMITTED	GWA RESPONSE
1	11/25/25	"We are a prospective bidder for subject mentioned project and submitting few question related to the project for your review and response.	
		RFI – 2025-1125-001 Subject: Design for temporary shoring Currently the structure is supported with temporary shoring and those shoring to remain during retrofit of the structure. Some of the props needs to be relocated during construction to accommodate workspace for new construction.	RFI – 2025-1125-001 Response: Contractor shall provide a shoring plan, including shoring jack capacity, spacing, and locations, for review and approval by the EOR.
		Q1: Confirm that contractor don't need to provide the design calculation for temporary shoring during construction and DOR has completed the design. Copy of the design will be provided to contractor upon award of the project.	
		RFI – 2025-1125-002 Subject: Roof drain/downspout pipe During the site visit it was observed that roof drain along the damaged column was broken.	RFI – 2025-1125-002 Response: Contractor shall repair or replace all damaged downspouts and roof drains in kind as part of the repair construction scope.

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913

P.O. Box 3010, Hagåtña, Guam 96932 Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

	Q1: Confirm that contractor shall re-install roof drain part of this contract. RFI – 2025-1125-003 Subject: Painting of new structure Q1: Confirm new structure needs to be painted matching color of existing structure."	RFI – 2025-1125-003 Response: Please refer to the attached revised specifications. The contractor shall paint the repaired area to match the existing building color.
2 11/26/25	"We would like to request a two-week extension for the bid submission deadline, moving it to December 19, 2025."	Response: No extension will be granted, and the deadline to submit the bid proposal remains December 5, 2025 at 3:00 PM .

Offerors are also notified to visit the GWA website, http://guamwaterworks.org/bids/ to ensure that addenda to the RFP, answers to questions, and reminders are communicated to all offerors throughout the solicitation process.

Brett E. Railey, P.E.

Acting General Manager

Brott ERailey

cc: MCB, EQ