




GUAM WATERWORKS AUTHORITY
 Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913
 P.O. Box 3010, Hagåtña, Guam 96932
 Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

**IFB No. 2026-08
 Flygt Brand Equipment
 Response for Inquiries No. 1**

This document addresses inquiries regarding IFB 2026-08. It provides clarifications and additional information for informational purposes. In the event that any responses result in modifications to the bid documents, they should be considered as amendments to the original IFB 2026-08.

QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
Questions from May 6 & 7, 2026	
1. Could you please provide photos of the nameplates for these pumps?	Photos of the pump nameplates are currently unavailable. Bidders are advised to refer to the specifications and requirements provided within the bid packet for the required Flygt NP3231.716 Pump Assembly and associated components.
2. Can you advise if only one MAS controller required?	The bid requires one (1) complete Flygt Pump Monitor MAS800 CU and one (1) complete Flygt Pump Monitor MAS800 BU812 for each Flygt NP3231.716 Pump Assembly. The total bid quantity consists of two (2) complete pump assemblies. Bidders are advised to strictly adhere to the specifications and requirements outlined in the bid packet.

Bidders are also notified to visit the GWA website: www.guamwaterworks.org to ensure that any addenda to the bid, answers to questions, and reminders are communicated to all bidders during the solicitation process.



 Thomas F.A. Cruz, P.E.
 Acting General Manager
CF

5/12/2026

 Date