



GUAM WATERWORKS AUTHORITY
 Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913
 P.O. Box 3010, Hagåtña, Guam 96932
 Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

IFB No. 2026-08
Flygt Brand Equipment
Response for Inquiries No. 2



This document addresses inquiries regarding IFB 2026-08. It provides clarifications and additional information for informational purposes. In the event that any responses result in modifications to the bid documents, they should be considered as amendments to the original IFB 2026-08.

QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
Questions from May 21, 22 & 25, 2026	
<p>1. Just to be clear trying to figure out who is installing the equipment if there was no pre-bid conference.</p> <p>We as a supplier of equipment are not staffed to install equipment.</p> <p>Is GWA going to be ok if we exclude installation from our quote?</p>	<p>REMOVAL OF INSTALLATION AND COMMISSIONING REQUIREMENTS</p> <p>The installation and commissioning requirements for Line-Item No. 1 and Line-Item No. 2 are hereby removed from this solicitation.</p> <p>GWA will perform the installation of the equipment in-house. Accordingly, the awarded vendor shall not be responsible for installation, commissioning, start-up services, testing, operational verification, or placement into service for Line-Item No. 1 and Line-Item No. 2.</p> <p>All references within the solicitation requiring such services by the awarded vendor for Line-Item No. 1 and Line-Item No. 2 are hereby deleted and shall no longer apply.</p> <p>All warranty provisions related to defects in materials, workmanship, and supplied equipment shall remain in full force and effect in accordance with the solicitation requirements.</p> <p>All other terms and conditions of the solicitation shall remain unchanged. This amendment shall become part of the solicitation documents.</p>
<p>2. Could we also request the required flow rate and head capacity so we can properly size the pump impeller based on the existing pump model requirements? This will help us provide a more accurate sizing, pricing and availability.</p> <p>Additionally, we would like to request a two-week extension for this bid to allow sufficient time to complete our evaluation and</p>	<p>Please be advised that the required pump performance shall be based on a head capacity of 152 feet and a flow rate of 3,000 GPM. Vendors should ensure that the proposed equipment is properly sized and capable of meeting or exceeding these minimum operational requirements.</p> <p>Please refer to Bid Amendment No. 1, in which</p>

IFB No. 2026-08
 Flygt Brand Equipment
 Response for Inquiries No. 2

	submission.	the Bid Submission and Opening Dates have been revised.
3.	<p>For additional clarification, there is a distinct difference between equipment suppliers and contractors. Contractors require specific licenses and insurance to perform installation work. Equipment suppliers do not carry any contracting licenses and carry different insurance that does not allow us to perform onsite construction work.</p> <p>Furthermore, this bid does not include any drawings or specific requirements for installation, so how is anyone supposed to provide a scope for that work? Demolition work? Electrical work? Mechanical work? Structural work?</p> <p>Our suggestion would be to amend the bid excluding installation and have this as a pure equipment purchasing bid and then put out another bid for proper installation.</p>	Please refer to the response provided to Question No. 1 regarding the removal of installation and commissioning requirements from this solicitation.
4.	<p>We would like to respectfully request a two-week extension of the bid submission deadline for the Flygt Brand Equipment.</p> <p>The additional time would greatly help us ensure a thorough, accurate, and competitive submission.</p>	Please refer to Bid Amendment No. 1, in which the Bid Submission and Opening Dates have been revised.

Bidders are also notified to visit the GWA website: www.guamwaterworks.org to view updates, addenda to the bid, answers to questions, and reminders. These details are updated on the GWA website for all bidders and the general public during the solicitation process.



5/28/2026

Miguel C. Bordallo, P.E. Date
 General Manager