




**GUAM WATERWORKS AUTHORITY**  
 Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913  
 P.O. Box 3010, Hagåtña, Guam 96932  
 Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

**Ypao and Mamajanao Wastewater Pump Station Rehabilitation**  
**GWA Project No. 22607**  
**IFB-05-ENG-2026**  
**GWA RFI Response No. 2 to Inquiries**

This Addendum and/or Response to Request for Information (RFI) is issued to modify the previously issued IFB documents and/or given for informational purposes and to the extent the responses below modify the IFB documents, please treat them as an amendment to the IFB. The following responses are in response to RFIs received.

	DATE	QUESTION/INQUIRY AS SUBMITTED:	GWA RESPONSE:
1	7/2/26	Hi Jana,  I understand the RFI submission period has closed, but in case there is an extension, we would like to submit the following for your consideration: <b>Note 3a on sheet C-04 states "Install new pumps, piping and valves at old YPAO". There are no drawings, specifications, or piping details for the "Old Ypao Pump Station" included in the IFB package. Based on the information provided, our understanding is that the new pumps are intended only for the new building. Please clarify the intended scope of work for the old Ypao building and confirm whether GWA's plan is to operate both the new and existing pump stations simultaneously after completion of the work.</b>	Response from EOR: The proposed Phase 3 Installation at Old Ypao notes will be deleted (3a. and 3b.). See Addendum 5.

Bidders are also notified to visit GWA website: [www.guamwaterworks.org/bids](http://www.guamwaterworks.org/bids) to ensure that addenda to the IFB, answers to questions, and reminders are communicated to all bidders throughout the solicitation process.

  
 \_\_\_\_\_  
 Christopher Budasi,  
 Acting General Manager 