

GUAM WATERWORKS AUTHORITY

Gloria B. Nelson Public Service Building | 688 Route 15, Mangilao, Guam 96913

P.O. Box 3010, Hagåtña, Guam 96932

Tel. No. (671) 300-6846/48 Fax No. (671) 648-3290

IFB No. 2026-34 Motive Pump Rebuild Response for Inquiries No. 1

This document addresses inquiries regarding IFB 2026-34. It provides clarifications and additional information for informational purposes. In the event that any responses result in modifications to the bid documents, they should be considered as amendments to the original IFB 2026-34.

QUESTION/INQUIRY AS SUBMITTED:		GWA RESPONSE:
Questions from September 11, 2026		
1.	Will GWA disconnect and reconnect any/all electrical or motor components?	Disconnection and reconnection of electrical or motor components are not required as part of the rebuild work. GWA will be responsible for <u>disconnection and reconnection of motive pump.</u>
2.	Will GWA remove and deliver the pump or require the contractor to remove and install?	GWA will deliver the pump to the awarded vendor for the required rebuild services. <u>Regarding installation, see response to #4.</u>
3.	Will GWA provide electrical lockout/tagout if required?	Electrical lockout/tagout (LOTO) is not required, as the pump has already been removed from service.
4.	With regards to operational testing, will this take place on-site or be required at contractor's facility? If on-site, will GWA provide power and authorized personnel for operational testing with contractor on-site to confirm functional operation?	GWA will be response for disconnection and reconnection of motive pump. Operational testing will be conducted following installation. <u>The awarded vendor is encouraged to be present during operational testing to assist in confirming proper functionality of the rebuilt pump.</u>
5.	What is the working pressure to perform the pressure testing that is required SOW?	GWA recommends that the test pressure does <u>not exceed 15 psi.</u>

Bidders are also notified to visit the GWA website: www.guamwaterworks.org to ensure that any addenda to the bid, answers to questions, and reminders are communicated to all bidders during the solicitation process.



 Miguel C. Bordallo, P.E.
 General Manager

9/15/2026

Date